## Village of Evendale Ice Arena Log of Air Quality Testing

Facility Name:	Arena Name (if applicable):				
Time Period of Log:	Arena Manager Signature:				
3	ice. Measurements should be taken 20 minutes after completion of a osed to the public, measurement should be taken prior to reopening.				
Combustion-powered edger: at least <b>once</b>	3 3				
Other fuel-hurning equipments if open to	the public every 15 minutes: if not open prior to opening next day				

Logs must be available when open to public. Submit a copy of the logs to the Evendale Fire Department by: Jan. 15, April 15, July 15, Oct. 15

Acceptable air quality: Carbon Monoxide < 20 ppm, Nitrogen Dioxide < 0.3 ppm. Exceedances must be reported to the Evendale Fire department. Please see "Indoor Ice Arena Exceedance Form" for further information.

Date	Equipment R=resurfacer E=edger; or Name other	Time Note: AM/PM	Number of Previous Resurfaces <b>Today</b>	Carbon Monoxide <sup>(</sup> pp <sup>m)</sup>	Nitrogen Dioxide (ppm)	Device Maintenance L=Leak Test B= Bump Test c= Calibration	Printed Name
_							